



TYPICAL SECTION
NO SCALE

NOTES

1. CONCRETE — PennDOT Class A-3300 PSI at 28 Days
2. FINISH — Wood Float Finish Curbing, Broom Finish Sidewalks
3. EXPANSION JOINTS — 1/2" Thick Premolded Bituminous, Expansion Joints
Not more than 30' Apart and along all structures
4. CONSTRUCTION JOINTS — Equally Spaced, Between Expansion Joints at Intervals
Not to Exceed the Width of the Sidewalk and at 10' Intervals for Curbing
5. CURING — Apply a Membrane Concrete Curing Compound or Other Approved
Curing Methods { PennDOT Cool/Cold Weather Curing required using 2" min. Insulating
Mats between 50° - 14° F }
6. DRIVEWAY CROSSOVERS
 - A. RESIDENTIAL — 6" Depth Concrete Full Width to Depressed Curb,
Maximum Length 30'
 - B. COMMERCIAL — 7" Depth with 6"x6"x6 Welded Wire Reinf. Full Width
to Depressed Curb, Max. Lgth. 35'
7. RAMPS for Handicapped Shall be Provided at All Street Intersection Preferably at the Midpoint
8. CONSTRUCTION & MATERIALS Shall Comply with Current PENNDOT Form 408
Specifications
9. CURB CONSTRUCTION REQUIRES A STRAIGHT PAVEMENT SAWCUT PRIOR TO EXCAVATING THE STREET SIDE. IF THE PAVEMENT EDGE BECOMES JAGGED DURING EXCAVATING, ANOTHER SAWCUT IS REQUIRED. THE STREET SIDE BACKFILL SHALL BE CLEANED OUT OF ALL DEBRIS AND FILLED WITH 2A MOD. STONE — TAMPED IN TWO (2) LIFTS UNDER OUR

TOWNSHIP OF WHITEHALL

STANDARDS
FOR
CONCRETE CURB & SIDEWALK
CONSTRUCTION & MATERIALS